

Certificate



SIL/PL
Capability

www.tuv.com
ID 0600000000

No.: 968/V 1030.00/17

Product tested Quick Exhaust Valves **Certificate holder** Ruelco, Inc.
1209 Distributors Row
New Orleans, LA 70123
USA

Type designation RQ-1, RQ-2

Codes and standards IEC 61508 Parts 1-2 and 4-7:2010

Intended application Safety Function: The Quick Exhaust Valves allows a fast venting of the outlet pressure through the vent port.

The valves are suitable for use in a safety instrumented system up to SIL 2 (low demand mode). Under consideration of the minimum required hardware fault tolerance HFT = 1 the valves may be used in a redundant architecture up to SIL 3.

Specific requirements The instructions of the associated Installation, Operating and Safety Manual shall be considered.

Summary of test results see back side of this certificate.

Valid until 2022-12-07

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/V 1030.00/17 dated 2017-12-07.

This certificate is valid only for products which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2017-12-07

Certification Body Safety & Security for Automation & Grid

Dipl.-Ing. Stephan Häb

www.fs-products.com
www.tuv.com

TÜVRheinland
Precisely Right.

Holder: Ruelco, Inc.
1209 Distributors Row
NEW ORLEANS LA 70123
USA

Product tested: Quick Exhaust Valves
RQ-1, RQ-2

Results of Assessment

Route of Assessment		2 _H / 1 _S	
Type of Sub-system		Type A	
Mode of Operation		Low Demand Mode	
Hardware Fault Tolerance	HFT	0	
Lambda Dangerous confidence level of calculation 1- α = 95 %	λ_D	1.50 E-07 / h	150 FIT
Lambda Dangerous Undetected assumed Diagnostic Coverage DC = 0 %	λ_{DU}	1.50 E-07 / h	150 FIT
Mean Time To Dangerous Failure	MTTF _D	6.65 E+06 h	760 a
Average Probability of Failure on Demand 1oo1 assumed Proof Test Interval T ₁ = 0.083 (once every month)	PFD_{avg}(T₁)	5.49 E-05	
Average Probability of Failure on Demand 1oo2 assumed Proof Test Interval T ₁ = 0.083 (once every month) assumed β_{1oo2} = 10 %	PFD_{avg}(T₁)	5.49 E-06	

Origin of values

The stated values are the results of the analysis of field feedback of the last five years. Random and systematic failures which are the responsibility of the manufacturer were examined.

Systematic Capability

The development and manufacturing process and the functional safety management applied by the manufacturer in the relevant lifecycle phases of the product have been audited and assessed as suitable for the manufacturing of products for use in applications with a maximum Safety Integrity Level of 3 (SC 3).

Periodic Tests and Maintenance

The given values require periodic tests and maintenance as described in the Safety Manual. The operator is responsible for the consideration of specific external conditions (e.g. ensuring of required quality of media, max. temperature, time of impact), and adequate test cycles.